Real Time Implementation of Grid-connection controlusing Robust PLL for WECS in Variable SpeedDFIG-based on HCC

Fayssal AMRANE, Azeddine CHAIBA, Bruno FRANCOIS, Badreddine BABES

Abstract : This paper presents the experimental real time implementation of a grid-connection field-oriented control (FOC) for wind turbine based on a doubly fed induction generator(DFIG). A control law is synthesized using a hybrid FOCHysteresisCurrent Controller (HCC) in Rotor side converter(RSC) and the stator is connected to grid via robust PLL (phaselocked loop). The regulation is achieved below the synchronous speed (Hypo-synchronous mode). The implementation is realized using dSPACE1104 single board card control and acquisition interface. The obtained results of the proposed control presenthigh performance in steady and transient states with low THD of the stator injected current to the grid (<5%).

Keywords: Doubly fed induction generetor (DFIG), Field oriented control (FOC), Hysteresis current controller (HCC), Rotor side converter (RSC), dSPACE1104