

Real Time Implementation of Shunt Active PowerFilter (SAPF)for Harmonic suppression and PowerQuality Improvement

B. Babes, A. Bouafassa, L. Rahmani, N. Hamouda

Abstract: In this paper, A Shunt Active Power Filter (SAPF) is implemented using a dSPACEDS1104 processor to compensate harmonics and reactive power produced by nonlinearload. The reference source current is computed based on the measurement of harmonicsin the supply voltage and load current. A hysteresis based current controller has beenimplemented in a DSP processor for injecting the compensating current into the powersystem, so that SAPF allows suppression of the harmonics and reactive power componentof load current, resulting in a supply current that is purely sinusoidal. Simulation andexperimental results of the proposed SAPF to meet the IEEE-519 standards are presented.

Keywords : Harmonics, Power quality, Active power filter, hystérisis comparator, real time control